



हिन्दुस्तान स्टीलवकर्स कंन्स्ट्रकशन लिमिटेड

(भारत सरकार का एक उदयम)

एनबीसीसी (इंडिया) लिमिटेड की एक सहायक कम्पनी

निगमित कार्यालय : 5/1 कमिसेरियट रोड (हेस्टिंग्स), कोलकता - 700 022

HINDUSTAN STEELWORKS CONSTRUCTION LIMITED

(A Govt. of India Undertaking)

A Subsidiary of NBCC (India) Limited

Plot No. N-1/207, Ground Floor, IRC Village, Nayapalli, Bhubaneswar - 751015 (Odisha)

Regd. Office: P-34A, Gariahat Road (South) Kolkata - 700 031

Head Office: 5/1 Commissariat Road (Hastings), Kolkata - 700 022

दुरभाष : Phone : 0674-2554895, फैक्स : Fax :0674- 2554895 ई-मेल : E-mail : hscl_bbsr@rediffmail.com, Web-site : www.hscl.co.in

CIN: U27310WB 1964 GOI026118

No:- HSCL/ZH (Odisha)/2021/L- 3820

Date: - 08.06.2021

To, The Principal, Kendriya Vidyalay No.-5 Kalinga Nagar, Bhubaneswar, Odisha.

Name of work: Construction of "A" type school building for Kendriya Vidyalay No.-5, Kalinga Nagar, Bhubaneswar, Odisha.

Ref: 1. Veer Surendra Sai University of Technology letter no. VSSUT/Civil/1137 dtd. 04.12.2015.

2. KV-5 letter no. F.150112/KV-5/2021-22/1202 dtd. 19.05.2021

Dear sir,

Attested

As desired by you for structural stability & safety Certificate a copy for the same which had been already submitted which issued by VEER SURENDRA SAI UNIVERSITY of TECHNOLOGY, BURLA attached herewith for your kind information and your records please.

Thanking You,

for-Hindustan Steelworks Construction Limited

(Rajeev Kumar Mishra)

DGM (Engg.)

Zonal Head/Odisha

षाचार्य / PRINCIPAL केन्द्रीय विद्यालय न-५ / K.V.No.-5 भ्वनेश्वर / Bhubaneswar

ओडिशा / Odisha

VEER SURENDRA SAI UNIVERSITY OF TECHNOLOGY: BURLA

(Formerly, University College of Engineering, Burla, ESTD: 1956)

(A UGC Recognized State Government Unitary University by an Act of Orissa Legislative Assembly)

P.O. Engineering College, Burla, Dist: Sambalpur, Orissa, India- 768 018 www.vssut.ac.in



Phone No. 91-663-2430211(0) : 91-663-2430204 Fax

No. VSSUT/Civil/ 1/37

Dated-04/12/2015

To

The Head (projects)

Hindustan steelworks Construction Ltd.

Bhubaneswar-751015.

Sub:- Issue of Structural Stability Certificate in respect of KV No-5 Building works at Kalinga Nagar, Bhubanewar, Orissa.

Sir

This is with reference to your letter No-HSCL/BBSR/Head(Projects)/KV-5/2015-1234 Dt. 27/08/2015. Based on following in-site test carried out at different location of the KV No-5 Buildings, Kalinga Nagar, Bhubaneswar, Orissa, we hereby certify:

- 1. That all the structural Drawings furnished to us for vetting of design & specification has been vetted.
- 2. That the construction of the Buildings is as per approved drawings and specifications.
- 3. That the construction work confirms to approved principles of Building code of
- 4. That all buildings for which in-situ tests has been performed are found to be structurally safe and stable.
- 5. That the ND test conducted at site confirms to IS456:2000. M25 grade of concrete.

The overall observation and analysis regarding stability, the building is structurally stable and safe.

Sr. Instructor

(Countersigned by)

H.O.D. Civil Engg

Prof-in -Charge, Concrete Lab

Shyam Sunder Alch Project Engineer HSCL/Bhubaneswar

प्राचार्य / PRINCIPAL केन्द्रीय विद्यालय न-५ / K.V.No.-5 भुवनेश्वर / Bhubaneswar ओडिगा / Odisha